



1. THIS DETAIL IS ONLY REQUIRED FOR OPEN TRENCH CUT. DIRECTIONAL BORE SHALL BE 30" MIN BELOW SURFACE.
2. YELLOW ELECTRICAL CAUTION TAPE SHALL BE INSTALLED IN ALL TRENCHED LOCATIONS & BORING PITS. TAPE SHALL BE @ 12" DEEP.

REVISED: SEPT-2009	STREET LIGHTING - TYPICAL TRENCH DETAILS	STANDARD DETAIL
ISSUED: SEPT - 2009	CITY OF WEST PALM BEACH ENGINEERING SERVICES DEPT.	SL-8